AnTek Inc.

www.antekinc.com

AU-13434 34Vx2 1300VA Transformers



Onen Circuit Test (core loss test).

The 1300VA industrial toroidal power transformer has higher efficiency than EI transformers, typically around 95 to 99%. Because of the effective containment of the magnetic flux inside the core, toroidal transformer will have a lot less interference with adjacent components. It has very lower mechanical humming and lower heat generated.


These AU series transformers are specially designed to work on all standard 115V and 230V at 50Hz or 60Hz. These transformers have heavier gauge wires then the normal requirement to avoid the copper lost during the full power output. The dielectric leakage current test is up to 3500Vac in between primary and secondary coils.

This transformer comes with 2 rubber pads, holding disk and center bolt assembly.

Current input | Power lost

Tel: 201-991-3300

sales@antekinc.com



Open Circuit Test (core loss test).	• Ortage input	Ourien	tiliput	I OWEI 103t	
TEST CONDITION: Apply variable voltage to primary coils (in parallel). Set voltages 120 and 140VAC at 60Hz. No load on secondary coils. Measure the primary current and input power.	120V 140V	.06A .08A		7.7W 11.8W	
Short Circuit Test (copper loss test):	Voltage input	Curren	nt rated	Power lost	
TEST CONDITION: Short all secondary coils, and apply variable voltage to (parallel) primary coils. Vary the voltage from 0-20VAC at 60Hz and freeze the voltage at rated primary current.	3.0V	10.8A		32.5W	
Load Test (operation test):	Voltage output	Current output		Power output	
TEST CONDITION: Input 120VAC 60Hz to the primary coils (in parallel), Output 1 and 2 in parallel to load, and measure voltage and current at different load levels. These are test data for reference only.	35.5V 34.3V 33.2V	0.0A 17.1A 39.8A		0W 588W 1323W	
DC Resistant Test: DC Milli-Ohm Meter: Test primary and secondary coils (value for each coil).	Primary		Se	Secondary	
	0.31 ohm		0.03 ohm		